



RAMONA MUNICIPAL WATER DISTRICT
In cooperation with the
CALIFORNIA DEPARTMENT OF FORESTRY
And FIRE PROTECTION

105 Earham Street
Ramona, California 92065-1599

Telephone:
1-760-788-2244

RAMONA FIRE PREVENTION BUREAU

David Sibbet
Department of Planning and Land Use
5201 Ruffin Rd. Ste. "B"
San Diego, California 92123-1666

January 22, 2010

Re: REVISED SALVATION ARMY FIRE PROTECTION PLAN, P70-379W²
APN:32203002, 10, 32203101, 02, 05, 32206001, 08, 09, 10,
32206103, 32701129 (806.62 acres)
14486 Mussey Grade Road
Ramona Ca.92065

We have reviewed subject latest Revised Fire Protection Plan (FPP)- Report dated January 21, 2010, prepared by DUDEK, 605 Third Street Encinitas, California 92024 Contact: Michael Huff, Manager.

There are practical difficulties in the creation of a secondary ingress/egress roadway.
The strict interpretation of the code regarding dead end road length is impossible
Due to practical difficulties.

The modification meets the intent and purposes of the code (section 104.8 of the 2009 consolidated Fire code) and the modification does not lesson health, and fire safety requirements.

Saul Villagomez Battalion Chief
Fire Marshal
CAL FIRE/Ramona Fire